

West Overton Utility District's Consumer Confidence Report-2022

Is my drinking water safe?

Yes, our water meets all of EPA's Health Standards. In 2022, over 32,635 tests for over 86 contaminants that may be in our drinking water were conducted by our suppliers. As you will see in the Water Quality Data charts on the next pages, only 9 of these contaminants were detected, and all of those were found to be within acceptable limits.

What is the source of my water?

We purchase treated water from The City of Livingston, and The City of Algood which purchases treated water from The City of Cookeville. The Livingston Water Treatment plant has three surface water intakes. One is located on Carr Creek impoundment (city lake) a 52-acre surface reservoir, while the other is located on Roaring River to supplement the supply in the impoundment. In August 2009 Livingston started getting water from the Cumberland River as their main water source. The Livingston Water Treatment Plant serves a population of approximately 15,010 and is designed to treat 4 million gallons per day (MGD). In 2022 the average daily flow pumped to consumers was 2.997 MGD. Our Algood supply, which is surface water, comes from the Center Hill Lake (Mine Lick Creek). The City of Cookeville Water Treatment Plant is designed to treat 15 million gallons per day (MGD). In 2022 the average daily flow pumped to customers was 12.367 MGD. The 2022 average Hardness was 74.5 ppm or 4.35 grams/gallon with a PH of 8.1.

Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to *potential* contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for untreated water sources serving this water system. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible (high), moderately susceptible (moderate), or slightly susceptible (low) based on geologic factors and human activities in the vicinity of the water source. The Livingston and Cookeville sources both rated as moderately susceptible to potential contamination. An explanation of Tennessee's SWAPS, the Source Water Assessment summaries, susceptibility scorings and overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the City of Livingston or the City of Cookeville to obtain copies of specific assessments.

Think Before You Flush

Flushing unused or expired medications can be harmful to your drinking water. Properly Disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take back bins. There are over 340 take back bins located across the state in all 95 counties, to find a convenient location please visit: <http://tdeconline.tn.gov/rxtakeback/> .

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Community water systems are required to release the detection of contaminants; however, bottled water companies are not required to comply with this regulation. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

How can I get involved?

If you have any concerns or questions please call or come by our offices. The Board of Commissioners meets on the fourth Tuesday of each month at 5:00 PM. The Commissioners of the West Overton Utility District serve four year terms. Vacancies on the Board of Commissioners are filled by appointment of the County Mayor / Executive. Decisions by the Board of Commissioner on customer complaints brought before the Board of Commissioners under the District's customer complaint policy may be reviewed by the Utility Management Review Board of the Tennessee Department of Environment and Conservation pursuant to Section 7-82-702(7) of Tennessee Code Annotated. A vacancy on the District's Board of Commissioners will exist on October 16, 2023 due to the expiration of the term of a current member of the Board. The Board plans to certify a list of three nominees to the Overton County Mayor to fill this vacancy at its regular meeting on July 25, 2023. A customer may submit a name for consideration by the Board for the list of nominees. To be considered the name must be mailed to the District's General Manager no later than one week before this Board meeting. If you have items that you wish to address, please call our Business office at (931) 498-4144 to be placed on the Board agenda. For more information about your drinking water, please contact Terry Walker at (931) 498-4144.

Is our water system meeting other rules that govern our operations?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- *Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- *Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.*
- *Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.*
- *Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.*
- *Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities*

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. For more information call EPA hot line at (800-426-4791).

TASTE AND ODOR

For the most part taste and odor problems are the result of iron, algae, and manganese. Our suppliers use additives such as hydrogen peroxide and activated carbon in an effort to eliminate these problems.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about their personal sanitation, food preparation, handling infants and pets, and drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). Some people who drink water containing trihalomethanes in excess of the MCL of 80 PPB over many years may experience problems with liver, kidneys, or central nervous systems, and have an increased risk of getting cancer.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. West Overton Utility District and our suppliers are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water,

you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

For more information about your drinking water, please call us at (931) 498-4144 or come by the office located at 684 Rickman Monterey Hwy, Rickman, TN 38580.

Water Quality Data

What does this chart mean?

! **MCLG**: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

! **MCL**: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

! Discretionary language regarding the use of averages to report levels of some contaminants.

West Overton Utility District

Contaminant	Do We Meet The Standards	MCLG in CCR units	MCL in CCR Units	Level found in CCR Units	Range of detections	Units	Date of sample	Typical source of Contaminant
Microbiological Contaminants								
Total Coliform Bacteria	YES	0	<2		Pos-Neg	#	*	Naturally present in the environment
Of 120 distribution samples collected in 2022 one tested positive for Total Coliform Bacteria and E. Coli all repeat samples tested negative. We meet the treatment technique.								
Inorganic Contaminants								
Copper ^{3*}	YES	1.3	AL=1.3 PPM	0.105 PPM	.00425 to .161	PPM	8/31/22	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead ^{4*}	YES	0	AL=15 PPB	ND PPB	ND to 4.65	PPB	8/31/22	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Chlorine	YES	MRDLG = 4	MRDL = 4	1.79	1.0 – 2.0	PPM	*	Water Additive used to control microbes
TTHMs [Total trihalomethanes] ^{6*}	YES		80	59.5 AVG	39.7 to 111	PPB	*	By-product of drinking water chlorination
Haloacetic Acids ^{5*}	YES		60	41 AVG	25.8 to 56.4	PPB	*	By-product of drinking water chlorination

City Of Algood

Contaminant	Do We Meet The Standards	MCLG in CCR units	MCL in CCR Units	Level found in CCR Units	Range of detections	Units	Date of sample	Typical source of Contaminant
Total Organic Carbons	YES	n/a	TT	n/a	1*	ppm	*	Naturally present in the environment
Turbidity ²	YES	n/a	TT	0.11	0.03 to 0.11	NTU	*	Soil runoff
Fluoride	YES	4	4	.122	0.04 to .12	ppm	*	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium	YES	No ne	None	22.3		ppm	*	Sodium Hydroxide is added to the treatment process for corrosion control and water stabilization
Synthetic Organic Contaminants including Pesticides and Herbicides		The City of Cookeville is waived on these except Atrazine, 2, 4d, Picloram and they were below the Detection Limit.						

City of Livingston

Contaminant	MCLG in CCR units	MCL in CCR Units	Level found in CCR Units	Range of detections	Violation	Date of sample	Typical source of Contaminant
Turbidity ²	N/A	TT	.25 NTU	.04 to .25 NTU	NO	01/01/22 to 12/31/22	Soil runoff
Total Organic Carbon ¹	30% required	TT	30% removed	.500 – 1.29 PPM	NO	01/01/22 to 12/31/22	Naturally present in the environment
Radium 226	0	3.0 pCi/L	0.53 pCi/L		NO	06/24/14	Erosion of natural deposits.
Inorganic Contaminants							
Fluoride	4 PPM	4 PPM	.52 PPM AVG	.48 - .57 PPM	NO	01/01/22 to 12/31/22	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium	n/a	n/a	4.01 PPM		NO	04/29/22	Sodium Hydroxide is added to the treatment process for corrosion control and water stabilization
Nitrate	10 PPM	10 PPM	.244 PPM		NO	04/07/22	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits

- * Most of the data presented in this table is from testing done between Jan. 1 - Dec. 31, 2022. We monitor for some contaminants less than once per year, and for those contaminants, the date of the last sample is shown in the table.
- 1* We meet the TT requirement for Total Organic Carbon in 2022. Cookeville was required to remove 27% and average removal was 64.1% based on 17 samples. Livingston met the Treatment Technique for Total Organic Carbon in 2022.
- 2* Turbidity does not present any risk to your health. We monitor turbidity, which is a measure of the cloudiness of water, because it is a good indicator that our filtration system is functioning properly.

The Livingston Treatment Plant met the Treatment Technique with 100% of monthly samples below the turbidity limit of 0.30 NTU.

Turbidity samples taken by the City of Cookeville in 2022 numbered 2,190 individual samples. 100% of all monthly samples were less than or equal to 0.30 NTU. Turbidity is monitored continuously. Our average turbidity for 2022 was 0.05817 NTU.
- 3* Lead and copper values are reported in the 90th percentile values. During the most recent round of lead and copper testing zero sites out of twenty sites exceeded the copper action level.
- 4* Lead and copper values are reported in the 90th percentile values. During the most recent round of lead and copper testing zero sites out of twenty sites exceeded the lead action level.
- 5* Some people who drink water containing haloacetic acids in excess of the MCL of 60 PPB over many years may have an increased risk of getting cancer. If you have specific health concerns, consult your doctor.
- 6* Some people who drink water containing trihalomethanes in excess of the MCL of 80 PPB over many years may experience problems with liver, kidneys, or central nervous systems, and have an increased risk of getting cancer. . **(You must drink at least 2 liters of water every day for 70 years and even then just one person in 10,000 may have a greater chance of getting cancer).**

Abbreviations: • CCR: Consumer Confidence Report • PPB: parts per billion or micrograms per liter • PPM: parts per million or milligrams per liter • n/a: not applicable • NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water • pCi/l: picocuries per liter (a measure of radioactivity) • AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. • TT: Treatment Technique or a required process intended to reduce the level of a contaminant in drinking water. • Avg: average. • MRDL or Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. • MRDLG: maximum residual disinfectant level, or level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. • ND: Non-detect